

**RICHLAND COUNTY GOVERNMENT
UTILITIES DEPARTMENT**

7525 Broad River Road, Irmo, SC 29063
T 803-401-0050 | F 803-401-0030
rcu_services@richlandcountysc.gov | richlandcountysc.gov



NOTICE OF SANITARY SEWER OVERFLOW

Date: October 2, 2020

The Richland County Utilities Department has experienced a sanitary sewer overflow caused by electrical failure at Pump station located near Hiller Road in Chapin.

The sewage spill may have affected the creek near Timmons Road in Chapin near Lake Murray.

An estimated 2,200 gallons of sewage was released. SC Department of Health and Environmental Control has been notified. Crews have made the necessary repairs and clean-up.

Citizens are advised that creek water quality in this area may be degraded until further notice. Richland County Utilities will be monitoring the area with creek water quality analysis.

For further information, citizens may contact the Richland County Utilities Department at (803) 401-0050.